



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

**Client:** Stohl Environmental  
3860 California Road  
Orchard Park, NY 14127

**Report Number:** 21-06-03811

**Received Date:** 06/23/2021  
**Reported Date:** 07/20/2021  
**Sampled By:** Christine Schultz  
**Tech Certification #:**

**Project/Test Address:** 2020L-121.8; Love Elementary School; 50 E 8th St; Jamestown, NY 14701

**Client Number:**  
33-5980

**Fax Number:**  
716-312-8092

# Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-06-03811-001	121.8-2	06/07/2021	CLASSROOM 6 SINK 1F-6	<1.00	07/19/2021	
21-06-03811-002	121.8-3	06/07/2021	CLASSROOM 6 BUBBLER 1A-23	<1.00	07/19/2021	
21-06-03811-003	121.8-4	06/07/2021	CLASSROOM 4 SINK 1F-7	1.43	07/19/2021	
21-06-03811-004	121.8-5	06/07/2021	CLASSROOM 4 BUBBLER 1A-24	<1.00	07/19/2021	
21-06-03811-005	121.8-6	06/07/2021	CLASSROOM 2 SINK 1F-8	1.40	07/19/2021	
21-06-03811-006	121.8-7	06/07/2021	CLASSROOM 2 BUBBLER 1A-25	3.40	07/19/2021	
21-06-03811-007	121.8-8	06/07/2021	CLASSROOM 1 LEFT SINK 1F-10	6.08	07/19/2021	
21-06-03811-008	121.8-9	06/07/2021	CLASSROOM 1 RIGHT SINK 1F-9	10.1	07/19/2021	
21-06-03811-009	121.8-10	06/07/2021	CLASSROOM 1 BUBBLER 1A-1	<1.00	07/19/2021	
21-06-03811-010	121.8-11	06/07/2021	NURSE OFFICE 1F-4	2.48	07/19/2021	
21-06-03811-011	121.8-12	06/07/2021	NURSE LAV 1F-11	3.00	07/19/2021	
21-06-03811-012	121.8-13	06/07/2021	STAGE LAV 1F-12	7.19	07/19/2021	
21-06-03811-013	121.8-14	06/07/2021	KITCHEN 3 BAY LEFT 1F- 5/1F-42	10.3	07/19/2021	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 21-06-03811

**Project/Test Address:** 2020L-121.8; Love Elementary School; 50 E 8th St;  
Jamestown, NY 14701

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-06-03811-014	121.8-15	06/07/2021	CLASSROOM 11 SINK 1F-23	1.09	07/19/2021	
21-06-03811-015	121.8-16	06/07/2021	CLASSROOM 11 BUBBLER 1A-7	<1.00	07/19/2021	
21-06-03811-016	121.8-17	06/07/2021	CLASSROOM 12 SINK 1F-22	1.48	07/19/2021	
21-06-03811-017	121.8-18	06/07/2021	CLASSROOM 12 BUBBLER 1A-6	<1.00	07/19/2021	
21-06-03811-018	121.8-19	06/07/2021	CLASSROOM 13 SINK 1F-21	2.04	07/19/2021	
21-06-03811-019	121.8-20	06/07/2021	CLASSROOM 13 BUBBLER 1A-5	<1.00	07/19/2021	
21-06-03811-020	121.8-21	06/07/2021	CLASSROOM 14 SINK 1F-20	1.68	07/19/2021	
21-06-03811-021	121.8-22	06/07/2021	CLASSROOM 14 BUBBLER 1A-4	<1.00	07/19/2021	
21-06-03811-022	121.8-23	06/07/2021	CLASSROOM 15 SINK 1F-19	1.82	07/19/2021	
21-06-03811-023	121.8-24	06/07/2021	CLASSROOM 15 BUBBLER 1A-3	1.10	07/19/2021	
21-06-03811-024	121.8-25	06/07/2021	CLASSROOM 16 SINK 1F-18	11.1	07/19/2021	
21-06-03811-025	121.8-26	06/07/2021	CLASSROOM 16 BUBBLER 1A-2	1.33	07/19/2021	
21-06-03811-026	121.8-27	06/07/2021	CLASSROOM 18 SINK 1F-41	8.90	07/19/2021	
21-06-03811-027	121.8-28	06/07/2021	CLASSROOM 18 LAV 1F-14	5.14	07/19/2021	
21-06-03811-028	121.8-29	06/07/2021	CLASSROOM 20 SINK 1F-42	9.00	07/19/2021	
21-06-03811-029	121.8-30	06/07/2021	CLASSROOM 20 BUBBLER 1A-26	1.71	07/19/2021	
21-06-03811-030	121.8-31	06/07/2021	CLASSROOM 19 SINK 1F-13	8.40	07/19/2021	
21-06-03811-031	121.8-32	06/07/2021	CLASSROOM 19 BUBBLER 1A-27	4.37	07/19/2021	
21-06-03811-032	121.8-33	06/07/2021	STAFF LAV RIGHT 1F-16	1.72	07/19/2021	
21-06-03811-033	121.8-34	06/07/2021	STAFF LAV LEFT 1F-17	1.88	07/19/2021	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 21-06-03811

**Project/Test Address:** 2020L-121.8; Love Elementary School; 50 E 8th St;  
Jamestown, NY 14701

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-06-03811-034	121.8-35A	06/07/2021	1ST FLOOR CORRIDOR FOUNTAIN 1C-1	<1.00	07/19/2021	
21-06-03811-035	121.8-35B	06/07/2021	1ST FLOOR CORRIDOR FOUNTAIN 1C-1	<1.00	07/19/2021	
21-06-03811-036	121.8-36	06/07/2021	SCHOOL COUNSELOR LAV 1F-39	3.41	07/19/2021	
21-06-03811-037	121.8-37	06/07/2021	CLASSROOM 30 SINK 1F-38	8.64	07/19/2021	
21-06-03811-038	121.8-38	06/07/2021	CLASSROOM 30 BUBBLER 1A-20	2.06	07/19/2021	
21-06-03811-039	121.8-39	06/07/2021	CLASSROOM 31 SINK 1F-37	7.61	07/19/2021	
21-06-03811-040	121.8-40	06/07/2021	CLASSROOM 31 BUBBLER 1A-19	1.47	07/19/2021	
21-06-03811-041	121.8-41	06/07/2021	CLASSROOM 32 SINK 1F-36	2.48	07/19/2021	
21-06-03811-042	121.8-42	06/07/2021	CLASSROOM 32 BUBBLER 1A-21/2A-21	1.13	07/19/2021	
21-06-03811-043	121.8-43	06/07/2021	CLASSROOM 33 SINK 1F-35	3.77	07/19/2021	
21-06-03811-044	121.8-44	06/07/2021	CLASSROOM 33 BUBBLER 1A-18	<1.00	07/19/2021	
21-06-03811-045	121.8-45	06/07/2021	CLASSROOM 34 SINK 1F-33	6.84	07/19/2021	
21-06-03811-046	121.8-46	06/07/2021	CLASSROOM 34 BUBBLER 1A-22	1.17	07/19/2021	
21-06-03811-047	121.8-47	06/07/2021	CLASSROOM 35 SINK 1F-34	7.69	07/19/2021	
21-06-03811-048	121.8-48	06/07/2021	CLASSROOM 35 BUBBLER 1A-17	1.68	07/19/2021	
21-06-03811-049	121.8-49	06/07/2021	CLASSROOM 36 SINK 1F-32	1.39	07/19/2021	
21-06-03811-050	121.8-50	06/07/2021	CLASSROOM 36 BUBBLER 1A-16	<1.00	07/19/2021	
21-06-03811-051	121.8-51	06/07/2021	CLASSROOM 37 SINK 1F-31	1.78	07/19/2021	
21-06-03811-052	121.8-52	06/07/2021	CLASSROOM 37 BUBBLER 1A-15	<1.00	07/19/2021	
21-06-03811-053	121.8-53	06/07/2021	CLASSROOM 38 SINK 1F-30	1.72	07/19/2021	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 21-06-03811

**Project/Test Address:** 2020L-121.8; Love Elemntary School; 50 E 8th St;  
Jamestown, NY 14701

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-06-03811-054	121.8-54	06/07/2021	CLASSROOM 38 BUBBLER 1A-14	<1.00	07/19/2021	
21-06-03811-055	121.8-55	06/07/2021	CLASSROOM 39 SINK 1F-29	1.44	07/19/2021	
21-06-03811-056	121.8-56	06/07/2021	CLASSROOM 39 BUBBLER 1A-13	<1.00	07/19/2021	
21-06-03811-057	121.8-57	06/07/2021	CLASSROOM 40 SINK 1F-28	1.47	07/19/2021	
21-06-03811-058	121.8-58	06/07/2021	CLASSROOM 40 BUBBLER 1A-12	<1.00	07/19/2021	
21-06-03811-059	121.8-59	06/07/2021	CLASSROOM 42 SINK 1F-27	2.27	07/19/2021	
21-06-03811-060	121.8-60	06/07/2021	CLASSROOM 42 BUBBLER 1A-11	<1.00	07/19/2021	
21-06-03811-061	121.8-61	06/07/2021	CLASSROOM 41 SINK 1F-26	1.79	07/19/2021	
21-06-03811-062	121.8-62	06/07/2021	CLASSROOM 41 BUBBLER 1A-10	<1.00	07/19/2021	
21-06-03811-063	121.8-63	06/07/2021	CLASSROOM 45 SINK 1F-25	8.67	07/19/2021	
21-06-03811-064	121.8-64	06/07/2021	CLASSROOM 45 BUBBLER 1A-9	<1.00	07/19/2021	
21-06-03811-065	121.8-65	06/07/2021	CLASSROOM 47 SINK 1F-24	3.17	07/19/2021	
21-06-03811-066	121.8-66	06/07/2021	CLASSROOM 47 BUBBLER 1A-8	<1.00	07/19/2021	
21-06-03811-067	121.8-67	06/07/2021	2ND FLOOR CORRIDOR FOUNTAIN	<1.00	07/19/2021	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 21-06-03811

**Project/Test Address:** 2020L-121.8; Love Elemntary School; 50 E 8th St;  
Jamestown, NY 14701

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

**Method:** EPA 200.8

**Analyst:** Ailea Cabatbat

**Accreditation #:** NY 11714

Reviewed By Authorized Signatory:

*Melissa Kanode*

*Missy Kanode*

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND                      ug/L= micrograms per liter                      ppb = parts per billion



3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-121.8

Client: Jamestown CSD

Contact: Carl Pillitteri

Building: Love Elementary School

Location: 50 E 8th St. Jamestown, NY 14701

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
<del>121.8-1</del>	<del>Basement Room 5 Janitor Service Connection [1S]</del>	S	3:03
121.8-2	Classroom 6 Sink [1F-6]	S	3:05
121.8-3	Classroom 6 Bubbler [1A-23]	B	3:07
121.8-4	Classroom 4 Sink [1F-7]	S	3:09
121.8-5	Classroom 4 Bubbler [1A-24]	B	3:11
121.8-6	Classroom 2 Sink [1F-8]	S	3:13
121.8-7	Classroom 2 Bubbler [1A-25]	B	3:15
121.8-8	Classroom 1 Left Sink [1F-10]	S	3:17
121.8-9	Classroom 1 Right Sink [1F-9]	S	3:19
121.8-10	Classroom 1 Bubbler [1A-1]	B	3:21
121.8-11	Nurse Office [1F-4]	S	3:23
121.8-12	Nurse Lav [1F-11]	S	3:25
121.8-13	Stage Lav [1F-12]	S	3:27
121.8-14	Kitchen 3 Bay Left [1F-5 / 1F-42]	S	3:29
121.8-15	Classroom 11 Sink [1F-23]	S	3:31
121.8-16	Classroom 11 Bubbler [1A-7]	B	3:33
121.8-17	Classroom 12 Sink [1F-22]	S	3:35
121.8-18	Classroom 12 Bubbler [1A-6]	B	3:37

21-06-03811



Due Date:  
07/22/2021  
(Thursday)  
AE

### Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

☒ If checked, also e-mail results to:

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 6/7/2021

Relinquished By: E. Henderson Print Name Stohl Env: Eric Henderson Jr. Date: 6/19/2021

Received (Name / Lab): RT HARRIS K. V. L. L. L. Date: 6-23-21 Time: 3:55 pm

Sample Login (Name / Lab): A. G. L. Date: 7/18/21 Time: 8:20 AM

Analysis (Name / Lab): A. C. L. Date: 7/19/21 Time: 6:30 pm

QA/QC Review (Name / Lab): M. L. Date: 7/20/21 Time: noon

Archived / Released:          QA/QC InterLAB Use:          Date:          Time:



3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-121.8

Client: Jamestown CSD

Contact: Carl Pillitteri

Building: Love Elementary School

Location: 50 E 8th St. Jamestown, NY 14701

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
121.8-19	Classroom 13 Sink [1F-21]	S	3:39
121.8-20	Classroom 13 Bubblers [1A-5]	B	3:41
121.8-21	Classroom 14 Sink [1F-20]	S	3:43
121.8-22	Classroom 14 Bubblers [1A-4]	B	3:45
121.8-23	Classroom 15 Sink [1F-19]	S	3:47
121.8-24	Classroom 15 Bubblers [1A-3]	B	3:49
121.8-25	Classroom 16 Sink [1F-18]	S	3:51
121.8-26	Classroom 16 Bubblers [1A-2]	B	3:53
121.8-27	Classroom 18 Sink [1F-41]	S	3:55
121.8-28	Classroom 18 Lav [1F-14]	S	3:57
121.8-29	Classroom 20 Sink [1F-42]	S	3:59
121.8-30	Classroom 20 Bubblers [1A-26]	B	4:01
121.8-31	Classroom 19 Sink [1F-13]	S	4:03
121.8-32	Classroom 19 Bubblers [1A-27]	B	4:05
121.8-33	Staff Lav Right [1F-16]	S	4:07
121.8-34	Staff Lav Left [1F-17]	S	4:09
121.8-35A	1st Floor Corridor Fountain [1C-1]	DF	4:11
121.8-35B	1st Floor Corridor Fountain [1C-1]	DF	4:13

### Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Christine Schultz Print Name Christine Schultz Stohl Env: Christine Schultz Date: 6/7/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 6/19/2021

Received (Name / Lab): K. Hansen Date: 6-23-21 Time: 3:41 pm

Sample Login (Name / Lab): A. Jones Date: 7/8/21 Time: 8:32 Am

Analysis (Name / Lab): A. A. Allen Date: 7/15/21 Time: 6:17 pm

QA/QC Review (Name / Lab): M. Miller Date: 7/20/21 Time: noon

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-121.8

Client: Jamestown CSD

Contact: Carl Pillitteri

Building: Love Elementary School

Location: 50 E 8th St. Jamestown, NY 14701

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
121.8-36	School Counselor Lav [1F-39]	S	4:15
121.8-37	Classroom 30 Sink [1F-38]	S	4:17
121.8-38	Classroom 30 Bubblers [1A-20]	B	4:19
121.8-39	Classroom 31 Sink [1F-37]	S	4:21
121.8-40	Classroom 31 Bubblers [1A-19]	B	4:23
121.8-41	Classroom 32 Sink [1F-36]	S	4:25
121.8-42	Classroom 32 Bubblers [1A-21 / 2A-21]	B	4:27
121.8-43	Classroom 33 Sink [1F-35]	S	4:29
121.8-44	Classroom 33 Bubblers [1A-18]	B	4:31
121.8-45	Classroom 34 Sink [1F-33]	S	4:33
121.8-46	Classroom 34 Bubblers [1A-22]	B	4:35
121.8-47	Classroom 35 Sink [1F-34]	S	4:37
121.8-48	Classroom 35 Bubblers [1A-17]	B	4:39
121.8-49	Classroom 36 Sink [1F-32]	S	4:41
121.8-50	Classroom 36 Bubblers [1A-16]	B	4:43
121.8-51	Classroom 37 Sink [1F-31]	S	4:45
121.8-52	Classroom 37 Bubblers [1A-15]	B	4:47
121.8-53	Classroom 38 Sink [1F-30]	S	4:49

### Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Christine Schultz Print Name Christine Schultz Date: 6/7/2021

Relinquished By: E. Henderson Print Name Eric Henderson Jr. Date: 6/19/2021

Received (Name / Lab): K. Mauer Date: 6/28/21 Time: 3:55 pm

Sample Login (Name / Lab): A. Touhy Date: 7/8/21 Time: 8:41 AM

Analysis (Name / Lab): A. C. Allen (Lab) Date: 7/19/21 Time: 6:31 pm

QA/QC Review (Name / Lab): meul Date: 7/20/21 Time: hmn

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





## Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-121.8

Client: Jamestown CSD

Contact: Carl Pillitteri

Building: Love Elementary School

Location: 50 E 8th St. Jamestown, NY 14701

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
121.8-54	Classroom 38 Bubbler [1A-14]	B	4:51
121.8-55	Classroom 39 Sink [1F-29]	S	4:53
121.8-56	Classroom 39 Bubbler [1A-13]	B	4:55
121.8-57	Classroom 40 Sink [1F-28]	S	4:57
121.8-58	Classroom 40 Bubbler [1A-12]	B	4:59
121.8-59	Classroom 42 Sink [1F-27]	S	5:01
121.8-60	Classroom 42 Bubbler [1A-11]	B	5:03
121.8-61	Classroom 41 Sink [1F-26]	S	5:05
121.8-62	Classroom 41 Bubbler [1A-10]	B	5:07
121.8-63	Classroom 45 Sink [1F-25]	S	5:09
121.8-64	Classroom 45 Bubbler [1A-9]	B	5:11
121.8-65	Classroom 47 Sink [1F-24]	S	5:13
121.8-66	Classroom 47 Bubbler [1A-8]	B	5:15
121.8-67	2nd Floor Corridor Fountain	DF	5:17

### Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Christine Schultz Print Name Christine Schultz Date: 6/7/2021

Relinquished By: E. Henderson Print Name Eric Henderson Jr. Date: 6/19/2021

Received (Name / Lab): K. Williams Date: 6-23-21 Time: 3:55 pm

Sample Login (Name / Lab): A. Jones Date: 7/8/21 Time: 8:47 AM

Analysis (Name / Lab): A. Alka Caballero Date: 7/19/21 Time: 6:21

QA/QC Review (Name / Lab): M. Mel Date: 7/20/21 Time: 1:00

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_