



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-06-03770

Received Date: 06/23/2021
Reported Date: 07/22/2021
Sampled By: Christine Shultz
Tech Certification #:

Project/Test Address: 2020L-121.3; Persell Middle School; 375 Baker St; Jamestown, NY 14701

Client Number:
33-5980

Fax Number:
716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-06-03770-001	121.3-1	06/08/2021	BOILER ROOM SINK 1S-1	38.4	07/21/2021	
21-06-03770-002	121.3-2A	06/08/2021	LOCKER ROOM CORRIDOR FOUNTAIN PUSH BAR 1C-7	<1.00	07/21/2021	
21-06-03770-003	121.3-2B	06/08/2021	LOCKER ROOM CORRIDOR FOUNTAIN BOTTLE 1C-7	<1.00	07/21/2021	
21-06-03770-004	121.3-3	06/08/2021	GIRLS LOCKER ROOM FOUNTAIN 1C-9	2.95	07/21/2021	
21-06-03770-005	121.3-4	06/08/2021	BOYS LOCKER ROOM FOUNTAIN 1C-8	2.10	07/21/2021	
21-06-03770-006	121.3-5	06/08/2021	KITCHEN HANDWASH 1F-8	22.3	07/21/2021	
21-06-03770-007	121.3-6	06/08/2021	FACULTY DINING ROOM 1F- 7	6.72	07/21/2021	
21-06-03770-008	121.3-7	06/08/2021	FACULTY LAV OUTSIDE FACULTY DINING ROOM 1F- 14	5.27	07/21/2021	
21-06-03770-009	121.3-8A	06/08/2021	CAFETERIA FOUNTAIN PUSH BAR 1C-6	<1.00	07/21/2021	
21-06-03770-010	121.3-8B	06/08/2021	CAFETERIA FOUNTAIN BOTTLE 1C-6	<1.00	07/21/2021	
21-06-03770-011	121.3-9	06/08/2021	NURSE 1F-6	2.60	07/21/2021	
21-06-03770-012	121.3-10A	06/08/2021	FOUNTAIN OUTSIDE ROOM 19 PUSH BAR 1C-5	<1.00	07/21/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-06-03770

Project/Test Address: 2020L-121.3; Persell Middle School; 375 Baker St;
Jamestown, NY 14701

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-06-03770-013	121.3-10B	06/08/2021	FOUNTAIN OUTSIDE ROOM 19 BOTTLE 1C-5	<1.00	07/21/2021	
21-06-03770-014	121.3-11	06/08/2021	FOUNTAIN OUTSIDE ROOM 16 1C-4	3.32	07/21/2021	
21-06-03770-015	121.3-12	06/08/2021	SINGLE LAV OUTSIDE ROOM 16 1F-15	5.59	07/21/2021	
21-06-03770-016	121.3-13A	06/08/2021	LIBRARY CORRIDOR EAST FOUNTAIN PUSH BAR 1C-3	<1.00	07/21/2021	
21-06-03770-017	121.3-13B	06/08/2021	LIBRARY CORRIDOR EAST FOUNTAIN BOTTLE 1C-3	1.49	07/21/2021	
21-06-03770-018	121.3-14B	06/08/2021	FOUNTAIN BY EXIT E3 BOTTLE 1C-2	<1.00	07/21/2021	
21-06-03770-019	121.3-15B	06/08/2021	LIBRARY CORRIDOR WEST FOUNTAIN 1C-1	<1.00	07/21/2021	
21-06-03770-020	121.3-16	06/08/2021	LIBRARY WEST SINGLE LAV LEFT 1F-13	6.65	07/21/2021	
21-06-03770-021	121.3-17	06/08/2021	LIBRARY WEST SINGLE LAV RIGHT 1F-12	16.2	07/21/2021	
21-06-03770-022	121.3-18	06/08/2021	ROOM 4 LAV 1F-11	4.81	07/21/2021	
21-06-03770-023	121.3-19	06/08/2021	ROOM 2 LAV 1F-9	10.6	07/21/2021	
21-06-03770-024	121.3-20	06/08/2021	ROOM 1 LAV 1F-10	21.6	07/21/2021	
21-06-03770-025	121.3-21	06/08/2021	HOME & CAREERS HALL SIDE SW 1F-0	7.50	07/21/2021	
21-06-03770-026	121.3-22	06/08/2021	HOME & CAREERS HALL SIDE NE 1F-1	11.0	07/22/2021	
21-06-03770-027	121.3-23	06/08/2021	HOME & CAREERS CENTER NE 1F-2	8.34	07/22/2021	
21-06-03770-028	121.3-24	06/08/2021	HOME & CAREERS WINDOW SIDE NE 1F-3	10.2	07/22/2021	
21-06-03770-029	121.3-25	06/08/2021	HOME & CAREERS WINDOW SIDE SW 1F-4	11.9	07/22/2021	
21-06-03770-030	121.3-26	06/08/2021	HOME & CAREERS WINDOW SIDE CENTER 1F-5	5.93	07/22/2021	
21-06-03770-031	121.3-14A	06/08/2021	FOUNTAIN BY EXIT E3 PUSH BAR 1C-2	1.78	07/22/2021	
21-06-03770-032	121.3-15A	06/08/2021	LIBRARY CORRIDOR NEXT FOUNTAIN 1C-1	<1.00	07/22/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-06-03770

Project/Test Address: 2020L-121.3; Persell Middle School; 375 Baker St;
Jamestown, NY 14701

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Ailea Cabatbat

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHs

STOHL Job # 2020L-121.3

Client: Jamestown CSD

Contact: Carl Pillitteri

Building: Persell Middle School

Location: 375 Baker St, Jamestown, NY 14701

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
121.3-1	Boiler Room Sink [1S-1]	S	22:00
121.3-2A	Locker Room Corridor Fountain - Push Bar [1C-7]	DF	22:02
121.3-2B	Locker Room Corridor Fountain - Bottle [1C-7]	DFB	22:04
121.3-3	Girls Locker Room Fountain [1C-9]	DF	22:06
121.3-4	Boys Locker Room Fountain [1C-8]	DF	22:08
121.3-5	Kitchen Handwash [1F-8]	S	22:10
121.3-6	Faculty Dining Room [1F-7]	S	22:12
121.3-7	Faculty Lav Outside Faculty Dining Room [1F-14]	S	22:14
121.3-8A	Cafeteria Fountain - Push Bar [1C-6]	DF	22:16
121.3-8B	Cafeteria Fountain - Bottle [1C-6]	DFB	22:18
121.3-9	Nurse [1F-6]	S	22:20
121.3-10A	Fountain Outside Room 19- Push Bar [1C-5]	DF	22:22
121.3-10B	Fountain Outside Room 19 - Bottle [1C-5]	DFB	22:24
121.3-11	Fountain Outside Room 16 [1C-4]	DF	22:26
121.3-12	Single Lav Outside Room 16 [1F15]	S	22:28
121.3-13A	Library Corridor East Fountain - Push Bar [1C-3]	DF	22:30
121.3-13B	Library Corridor East Fountain - Bottle [1C-3]	DFB	22:32
121.3-14B	Fountain by Exit E3 - Bottle [1C-2]	DFB	22:34

21-06-03770



Due Date:
07/22/2021
(Thursday)
AE

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 6/8/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Date: 6/19/2021

Received (Name / Lab): KTHARRIS K. Harris Date: 6-23-21 Time: 2:30pm

Sample Login (Name / Lab): Tracy Bloom / Shaw Brown Date: 7/1/21 Time: 9:59am

Analysis (Name / Lab): JC / Hilary Cabral Date: 7/22/21 Time: 1:14pm

QA/QC Review (Name / Lab): M. Miller Date: 7/22/21 Time: 1:4pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-121.3

Client: Jamestown CSD

Contact: Carl Pillitteri

Building: Persell Middle School

Location: 375 Baker St, Jamestown, NY 14701

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
121.3-15B	Library Corridor West Fountain [1C-1]	DFB	22:36
121.3-16	Library West Single Lav Left [1F-13]	S	22:38
121.3-17	Library West Single Lav Right [1F-12]	S	22:40
121.3-18	Room 4 Lav [1F-11]	S	22:42
121.3-19	Room 2 Lav [1F-9]	S	22:44
121.3-20	Room 1 Lav [1F-10]	S	22:46
121.3-21	Home & Careers Hall Side SW [1F-0]	S	22:48
121.3-22	Home & Careers Hall Side NE [1F-1]	S	22:50
121.3-23	Home & Careers Center NE [1F-2]	S	22:52
121.3-24	Home & Careers Window Side NE [1F-3]	S	22:54
121.3-25	Home & Careers Window Side SW [1F-4]	S	22:56
121.3-26	Home & Careers Window Side Center [1F-5]	S	22:58
121.3-14A	FOUNTAIN BY EXIT E3 - PUSH BAR [1C-2]	DF	22:34
121.3-15A	LIBRARY CORRIDOR WEST FOUNTAIN [1C-1]	DF	22:36

Notes:

Please e-mail lab results to labs@stohlenv.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 6/8/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 6/19/2021

Received (Name / Lab): RETHABHIS X STAW Date: 10-23-21 Time: 2:30 PM

Sample Login (Name / Lab): Travis Bloom / Shaw Bloom Date: 7/7/21 Time: 10:08 AM

Analysis (Name / Lab): Eric Henderson Jr. Date: 7/7/21 Time: 1:14 PM

QA/QC Review (Name / Lab): M. Henderson Date: 7/7/21 Time: 1:00 PM

Archived / Released: QA/QC InterLAB Use: Date: Time:

21-06-03770