



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

**Client:** Stohl Environmental  
3860 California Road  
Orchard Park, NY 14127

**Report Number:** 21-06-03711

**Received Date:** 06/23/2021  
**Reported Date:** 07/20/2021  
**Sampled By:** Christine Schultz  
**Tech Certification #:**

**Project/Test Address:** 2020L-121.11; Technical Academy; 200 E 4th St; Jamestown, NY 14701

**Client Number:**  
33-5980

**Fax Number:**  
716-312-8092

# Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-06-03711-001	121.11-2	06/07/2021	FIRST AID 1F-3	2.01	07/20/2021	
21-06-03711-002	121.11-3	06/07/2021	SINGLE LAV BY FIRST AID 1F-5	1.31	07/20/2021	
21-06-03711-003	121.11-4	06/07/2021	2ND FLOOR LEFT FOUNTAIN 1C-3	1.30	07/20/2021	
21-06-03711-004	121.11-5	06/07/2021	2ND FLOOR RIGHT FOUNTAIN 1C-4	<1.00	07/20/2021	
21-06-03711-005	121.11-6	06/07/2021	1ST FLOOR FOUNTAIN 1C-2	1.60	07/20/2021	
21-06-03711-006	121.11-7	06/07/2021	ROOM 103 LEFT SINK 1F-1	1.96	07/20/2021	
21-06-03711-007	121.11-8	06/07/2021	ROOM 103 RIGHT SINK 1F-4	4.93	07/20/2021	
21-06-03711-008	121.11-9	06/07/2021	1ST FLOOR LEFT SINGLE LAV 1F-6	1.86	07/20/2021	
21-06-03711-009	121.11-10	06/07/2021	1ST FLOOR RIGHT SINGLE LAV 1F-7	2.51	07/20/2021	
21-06-03711-010	121.11-11	06/07/2021	ROOM 101 SINK 1F-2	1.57	07/20/2021	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 21-06-03711

**Project/Test Address:** 2020L-121.11; Technical Academy; 200 E 4th St;  
Jamestown, NY 14701

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

**Method:** EPA 200.8

**Analyst:** Ailea Cabatbat

**Accreditation #:** NY 11714

Reviewed By Authorized Signatory:

*Melissa Kanode*

*Missy Kanode*

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND                      ug/L= micrograms per liter                      ppb = parts per billion



3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-121.11

Client: Jamestown CSD

Contact: Carl Pillitteri

Building: Technical Academy

Location: 200 E 4th St Jamestown, NY 14701

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
<del>121.11-1</del>	<del>Mechanical Room Service Line [1C-4]</del>	<del>S</del>	<del>2:45</del>
121.11-2	First Aid [1F-3]	S	2:47
121.11-3	Single Lav by First Aid [1F-5]	S	2:49
121.11-4	2nd Floor Left Fountain [1C-3]	B	2:51
121.11-5	2nd Floor Right Fountain [1C-4]	B	2:23
121.11-6	1st Floor Fountain [1C-2]	B	2:55
121.11-7	Room 103 Left Sink [1F-1]	S	2:57
121.11-8	Room 103 Right Sink [1F-4]	S	2:59
121.11-9	1st Floor Left Single Lav [1F-6]	S	3:01
121.11-10	1st Floor Right Single Lav [1F-7]	S	3:03
121.11-11	Room 101 Sink [1F-2]	S	3:05

21-06-03711



Due Date:  
07/22/2021  
(Thursday)  
AE

### Notes:

Please e-mail lab results to labs@stohlenvironmental.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 6/7/2021

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 6/19/2021

Received (Name / Lab): RTHARRIS R. Harris Date: 6-23-21 Time: 12:02 pm

Sample Login (Name / Lab): Trace Bloomfield Date: 7/6/21 Time: 5:12 PM

Analysis (Name / Lab): Alka Carb Date: 7/20/21 Time: 12:42 pm

QA/QC Review (Name / Lab): M. M. M. Date: 7/20/21 Time: 1:02 pm

Archived / Released: QA/QC InterLAB Use: Date: 7/20/21 Time: 1:02 pm